Faculty of Arts and Humanities

School of Art, Design and Architecture

2022-01

Living wall systems for improved thermal performance of existing buildings

Fox, M

http://hdl.handle.net/10026.1/18258

10.1016/j.buildenv.2021.108491 Building and Environment Elsevier

All content in PEARL is protected by copyright law. Author manuscripts are made available in accordance with publisher policies. Please cite only the published version using the details provided on the item record or document. In the absence of an open licence (e.g. Creative Commons), permissions for further reuse of content should be sought from the publisher or author.

Living wall systems for improved thermal performance of existing buildings

Matthew Fox, Jack Morewood, Thomas Murphy, Paul Lunt, Steve Goodhew

 PII:
 S0360-1323(21)00887-8

 DOI:
 https://doi.org/10.1016/j.buildenv.2021.108491

Reference: BAE 108491

To appear in: Building and Environment

Received Date: 19 July 2021

Revised Date: 19 October 2021

Accepted Date: 24 October 2021

Please cite this article as: Fox M, Morewood J, Murphy T, Lunt P, Goodhew S, Living wall systems for improved thermal performance of existing buildings, *Building and Environment* (2021), doi: https://doi.org/10.1016/j.buildenv.2021.108491.

This is a PDF file of an article that has undergone enhancements after acceptance, such as the addition of a cover page and metadata, and formatting for readability, but it is not yet the definitive version of record. This version will undergo additional copyediting, typesetting and review before it is published in its final form, but we are providing this version to give early visibility of the article. Please note that, during the production process, errors may be discovered which could affect the content, and all legal disclaimers that apply to the journal pertain.

© 2021 Published by Elsevier Ltd.



1 Title Page

2 Title

4

6

7 8

9

10

11

13

14

15

16

3 Living wall systems for improved thermal performance of existing buildings.

5 Authors

Matthew Fox^{a*}, Jack Morewood^a, Thomas Murphy^b, Paul Lunt^b, Steve Goodhew^a

a. University of Plymouth. School of Art, Design & Architecture, Drake Circus, Plymouth, United Kingdom, PL4 8AA

b. University of Plymouth. School of Geography, Earth and Environmental Sciences, Drake Circus, Plymouth, United Kingdom, PL4 8AA

12 Highlights

- Green and living facades can improve the thermal performance of existing buildings.
- There is a lack of empirical data on effects of living wall to building insulation.
- Findings demonstrate a 31% improvement to traditional masonry wall U-values.

17 Abstract

18 Living wall systems are a relatively new form of façade cladding treatment on buildings. Bringing a

- 19 host of benefits such as added biodiversity, they also have the potential to aid the thermal efficiency
- 20 of a wall construction by offering an extra layer of thermal resistance. Yet few studies have been

21 conducted to ascertain the thermal influence of living wall systems can have on existing buildings.

22

23 This study reviews the impact of living walls upon the thermal and environmental performance of

buildings and isolates a lack of research that directly measures associated retrofitted living wall

thermal performance. A case study then monitors the heat flux through a pre 1970s uninsulated

- 26 cavity masonry wall construction that has been retrofitted with an external living wall system face.
- 27 Results are compared with an identical wall build-up on the same elevation without the living wall
- 28 cladding.29
- **30** Results found that the calculated thermal transmission value for the pre 1970s wall with an additional
- 31 Living wall façade cladding was 31.4% lower than that of the same wall without the living wall.
- 32 Furthermore, diurnal fluctuations in heat flux were lower over the study period for the wall with the
- 33 living wall system cladding. These findings demonstrate that a living wall façade offers a viable
- 34 solution for helping to minimise heat loss from existing buildings of this construction.
- 35

36 Keywords

37 U-value, Living wall systems, Green walls, Heat flux, Insulation, Energy Conservation, Sustainable38 Buildings, Space Heating, Cladding.

39

40 Abbreviations

- 41 Green Façade (GF), Living wall systems (LWS), Root mean square (RMS).
- 42 U-value presented in watts per meters squared, Kelvin (W/m²K)
- 43

44 Word count: 6326

45

46 Funding

- 47 This research did not receive any specific grant from funding agencies in the public,
- 48 commercial, or not-for-profit sectors.

49 1. Introduction

50

In Britain, buildings directly account for 17% of UK Greenhouse Gas Emissions (85 MtCO₂e in 2019)
[1], and space heating accounts for over 60% of all energy used in buildings [2]. Whilst modern policy
and construction methods strive to minimise energy use, it is acknowledged that there is a correlation
between the age of buildings and increased energy in use [3], with older buildings being the largest
contributors to carbon emissions.

56

57 Within England, approximately 57% all domestic [4] and non-domestic [5] buildings were built before

58 1964. Many other existing conurbations across the globe have similar rates of pre-existing buildings

and therefore are likely to have associated thermal standards within their existing building fabric.
Therefore if the UK is to reach its target of net zero carbon emission by 2050 [6, 7], and other global

61 targets it will be critical to address the energy use of existing building stock.

62

63 One of the most common forms of construction in the UK, some parts of Europe, North America and

64 Asia since the 1920s are masonry walls, with cavity systems accounting for around 70% of UK

- dwellings [8]. The thermal performance of this form of construction is relatively poor, with measured
- 66 thermal transmission values in the region of 1.3 to 1.1W/m²K [9] and 1.56W/m²K [10] for masonry
- 67 cavity walls built before 1990. This date is significant, since the England and Wales building
- **68** regulations changed in 1990 to lower the thermal transmission value with nominal U-values for

69 external walls falling from $1.0W/m^2K$ in 1976 to $0.45W/m^2K$ in 1990 [11]. This led to increased use of

cavity fill insulation to meet the regulations. To date there are around 5.3 million UK properties (30%
of the total building stock) that do not have cavity insulation, many of which are perceived as being

- hard to treat* [8]. *(Hard to treat infers associated difficulties in installing either cavity, internal or
- 73 external wall insulation to lower the wall's thermal transmission value).
- 74

Strategies to improve the thermal performance of existing walls includes the use of cavity fill, internal
or external wall insulation [12]. Each method has unique practical benefits and limitations. The unique
features often alter the time related response of walls, leading to specific thermal performance
characteristics that can not only reduce heat loss but result in more comfortable interior spaces in

characteristics that can not only reduce heat loss but result in more ofextended periods of high external temperatures [13, 14]

80

Whilst insulation will reduce wall heat loss, it is estimated that wind driven convection can increase
heat loss from building surfaces by 50% [15]. This issue is recognised by Anderson [16] and BS EN
6946 [17], who estimate that exposed walls with a surface resistance of 0.04m²K/W can be improved
to between 0.1m²K/W and 0.13m²K/W (for high emissivity surfaces) if using some form of external
ventilated cladding / rain screen protecting the exposed surface. This could include the incorporation
of a container system used to provide the growing medium for housing plants close to an existing
wall.

87 88

89 Yet there is great complexity in estimating the flow of heat through a ventilated cavity due to a range90 of factors such as conduction within still air, convection from air movement and radiation from the

91 inner cavity surface. Sanders [18] suggest that the estimated U-value for a traditional timber framed

91 inner cavity surface. Sanders [18] suggest that the estimated U-value for a traditional timber framed
92 wall with a ventilated cavity to its cladding could vary by between 3% and 7% dependent on the

93 emissivity of the materials used and the degree of ventilation. Whilst much work has been

94 undertaken to consider the complexities of cavity resistances, Davies [19] comments on the limited

95 work that has been undertaken to verify the assumptions made for thermal resistances of ventilated

96 cladding cavities.

97

98 There are many options available for external claddings on buildings, however a relatively new form99 of external wall covering are 'green walls'. These green walls also known as 'vertical greening systems'

- **100** are typically categorised into Green Façade (GF) and living wall systems (LWS). Whilst GF use plants
- directed to grow from a single point (usually at ground level) up a trellis or framework, LWS differ bygrowing plants from multiple pockets of soil and other medium across the entire area of the façade
- 103
- 104

105 The aim of this paper is to investigate the potential for an external LWS to improve the fabric U-value106 of existing cavity walls. This shall be investigated through these objectives:

- 107 1. Review existing academic literature on GF and LWS.
- Investigate the change in fabric U-value to an existing uninsulated masonry cavity wall
 example case study when retrofitted with an external LWS façade cladding treatment.
- 110

111 2. Theory

[20].

Green wall systems offer a wide range of unique benefits [21] that more traditional inert façade
claddings such as timber or cementitious materials cannot provide. Benefits include enhanced sound
absorption [22], pollution mitigation and improvement in air quality [23], increased biodiversity [24],
added value from biodiversity [25], and psychological improvements from perceived organic aesthetic
[26, 27].

117

118 In the context of more traditional cladding / rain screens offering some improvement in surface

- resistance, several studies have been conducted to explore the benefits that green walls can have onthe thermal behaviour of buildings.
- 121

One area of previous research has focused on the reduction in the urban heat island effect in warm climates, where foliage from such façades minimises the direct solar exposure on more traditional thermally massive construction materials such as masonry [28], lowering the risk from re-emitted thermal radiation to the urban realm. By minimising the solar gains on buildings, green walls have also

- 125 thermal radiation to the urban reality by minimising the solar gains on buildings, green wais have also 126 been found to lower the indoor air temperature of buildings in warm climates through foliage offering
- shading to the façade [21]. Ottele et al., [15] explain how solar energy is used by the vegetation, with
- 128 5-30% being reflected, 5-20% used for photosynthesis, 10-50% turned into heat and 5-30%
- 129 transmitted through the leaf. They also add that 20-40% of the solar exposure is used for
- 130 evapotranspiration, which is the process of drawing heat through evaporated moisture from the leaf
- [21]. The net result is that the ventilated air gap between the green wall and the adjoining
- 132 construction is cooled by the foliage restricting the path of solar energy to the building. This is
- supported by Di & Wang [29] who found that peak cooling loads could be reduced by 28% for west
- 134 facing ivy covered walls when exposed to direct sunlight. Adding to this, Wong et al., [30] found that 135 wall surface temperatures could be reduced by over 11°C when using a vertical greenery system.
- wall surface temperatures could be reduced by over 11°C when using a vertical greenery system.
 Work by Safikhani & Baharvand [31] explored the effect of increasing the ventilated cavity on
- 137 lowering wall surface temperatures, and found that a 30cm cavity on western located walls provided
- 138 the most optimal solution when utilising a green wall for cooling. Also work by Cameron et al., [32]
- 139 has explored the effect that different forms of foliage have on cooling.
- 140
- Plant geometry varies according to the growth form with the majority of living wall plants consisting of evergreen, perennial, herbaceous species. This reflects the requirement for dense, low growing plants with attractive foliage all year round [33]. Dense foliage growth in evergreen perennials is most often associated with plants with meristems (growth points) occurring at ground level and typically have tussock forming or clumped growth forms. In addition to being aesthetically pleasing, dense foliage of clump forming grasses, ferns and flowering plants have the added ecosystem services of
- sequestering relatively large amounts of carbon in their foliage, plant tissues, and as soil organic
- 148 carbon [34]. As well as wall cover and shade this dense plant biomass may provide additional thermal
- insulation for buildings [35]. Tangjuank [36] found that the thermal insulation of particleboards
- 150 produced from pineapple leaves, which has a similar clumped growth form to a living wall staple,

Luzula spp. was 0.035 W/m.K with density of 210 kg/m3, which was closed to the commercialinsulator.

153

154 In addition to work undertaken on the cooling effects that can be gained from green walls, there is 155 some research into the insulative benefits that such a system can bring. There is evidence that an 156 external layer of foliage can lower the rate of heat loss from a building, particularly as it minimises 157 wind driven convective cooling by providing a buffer to wind [21]. Work by Eumorfopoulou & 158 Kontoleon [37] discuss the buffering of wind, suggesting that foliage creates pockets of still air 159 amongst the leaves, which reduce the heat transfer coefficient. The effect of this though is dependent 160 on the density of the foliage. Indeed, evidence from a green wall study in UK winter conditions 161 suggests the variation between recorded green façade energy saving of 21% and 37% compared to 162 bare walls was explained by plant establishment and foliage factors [38]. Cameron et al., [38] suggests 163 energy savings with this system could be as high as 40 - 50% in UK winter settings during periods of 164 extreme weather (strong rain and wind, cold). Further research by Yoshimi [39] show how a green 165 wall can provide an insulating effect by helping the external wall behind the green wall to maintaining 166 a higher and more stabilised surface temperature when compared with surface temperatures of an 167 external wall without a green wall. It is not just the external wall surface temperature that is reduced, 168 the air in the gap between the foliage and the wall is also warmer due to the buffering effect of the 169 leaves. Riley [33] indicates a 38% cost reduction in winter energy use resulting from the installation of 170 green walls

171

172 The insulating effect of foliage is found to be greater at night, when larger variations in air

temperature might be expected. This factor is supported by Nan et al. [40], who found LWS provide

an insulating effect during the evening and early morning. Riley [33] also reports that the greatestbenefits can be gained from green walls at the times of lowest and highest temperatures of the

176 heating and cooling season. By protecting the exposed wall during the coldest times of the day, there

is some levelling of diurnal wall temperatures, which will minimise heat flow through a structure.

178 Additional findings from Nan et al. [40] found that soil temperatures were greater than air

temperatures and that LWS helped to raise internal temperatures by between 0.4°C and 1.7°C

- 180 compared with walls without greenery. However, in winter the soil in the pockets of LWS is likely to
- 181 be wetter than summer, which Charoenkit & Yiemwattana [41] argue could lead to greater heat loss

in winter due to increased evaporative cooling. Dependent on the plant species, there is also an issue

183 related to the shedding of foliage in winter. Such loss of foliage might lower the insulating effect

184 suggested by others, though could lead to benefits from added solar exposure of the wall behind [42].185

186 If the more biologically orientated research linked to green and living walls is assessed, it is clear that
187 much can be learnt from natural systems where there is empirical data on how plant geometry and
188 leaf morphology is a determining factor for thermal performance in plants [43]. At present there is
189 limited work applying knowledge from natural habitats to options for different plant types in living

- wall systems [38].
- 191

192 Leigh et al., [44] has shown that leaf morphology and anatomy has a significant influence on leaf 193 surface thermal dynamics. Smaller leaves with increasing leaf dissection (pinnate or bipinnate) were 194 found to have higher levels of heat dissipation [44] and reduce water loss [45]. Smaller, thicker more 195 dissected leaves can be an advantage to plants growing on water stressed vertical surfaces of 196 buildings but provide lower levels of shading from solar radiation [44]. Larger leaves provide higher 197 levels of shade [46] and could be important in minimizing excessively high heat loads on building 198 surfaces. Rupp and Gruber [43] model heat transfer for different leaf shapes and found that shape-199 driven transfer enhancements were higher for models with small leaves with finely toothed edges, 200 with local cooling up to 10 °C below air temperature. Leaf surface is also important, increased leaf

surface pubescence (hair cover) and leaf margin complexity increase boundary layer thickness,

202 reducing leaf surface heating [43]. Pubescence and lighter-coloured leaves reflect more light

- providing added leaf surface cooling and water conservation [45, 47]. When assessing all of these
- variables Bau-Show Lin & Yann-Jou Lin [46] found that foliage density followed by leaf thickness, leaf
 texture, and leaf colour had the greatest contribution to surface-soil cooling. Further work on living
- wall systems is required to test these factors. There were some aspects that the review did not
- 207 provide definite answers to, such as the impact the type of organic matter has on thermal
- 208 performance. Similarly investigating the effect that irrigation has on soil and conductivity, whether
- 209 different plant species offer varied improvements in performance and exploring the effect that annual
- 210 growth has on overall performance. In some instances, this empirical data can be used to
- 211 model/simulate the possible building performance outcomes associated with different
- 212 plant/layout/substrate and existing walling options.
- 213

214 Many studies have focused on modelling [48, 49], simulation [42, 50-54], multi-layer temperatures
215 [30, 37, 55] and humidity [40] monitoring; however, few have used in-situ heat flux to assess thermal

- conductivity through LWS. Of those who have used heat flux methodologies, Mazzali et al., [56] have
- 217 investigated the rate of heat flux through foliage to the masonry wall behind. This was to assess the
- cooling properties of a LWS. In another study, Manso & Gomes [57] investigated a cork-based LWS
- attached to an insulated metal building in Portugal. Over three 14-day periods, they utilised
- temperature and heat flux monitoring. Results were promising and found that minimum internal
- surface temperatures could be increased by 7°C during winter periods with the addition of the cork
- based LWS. Additional work using heat flux investigations on LWS in a winter period was conducted
- by Tudiwer & Korjenic [58]. In this study, two types of living wall were investigated and compared
- with un-covered sections of wall. Results found that the LWS monitored gave between $0.13m^2$ K/W
- and 0.68m²K/W improvement in thermal resistance over non-greened walls. These findings are also
 promising and suggest that further work on different types of LWS is needed to better understand the
- winter period improvements that can be made by installing these systems to an existing building.
- 228

229 Despite previous work in this field, there remains a lack of research investigating the thermal 230 performance improvement that could be made to a traditional masonry cavity wall. In the UK, this is 231 significant, given the large number of existing masonry cavity walls present. Whilst traditional 232 strategies for improving the thermal resistance of such walls might have added insulation, literature 233 suggests that LWS could offer an alternative solution for thermal improvement, whilst also providing 234 other unique benefits such as biodiversity, aesthetic and air quality improvements. Furthermore, 235 understanding the scale of the thermal improvement offered in this setting will help define the 236 sustainability potential of this approach given the potentially high environmental lifecycle and overall 237 energy burden this system may exert [15].

238

239 Due to the limited research on thermal performance improvement from LWS on masonry cavity walls,240 a practical development from this theory was deemed necessary.

241

The following sections present an investigation into the thermal performance of an externally applied LWS façade cladding treatment placed over an existing uninsulated masonry cavity wall. The setting for this is Plymouth, UK, which is sited in a maritime climate. The objective will be to compare two identical sections of existing walling (one covered with the living wall) using heat flux sensors to determine whether any improvement can be made with the selected living wall system.

- 248 3. Material and Methods
- 249

250 3.1 The case study building

251 The building investigated under this study is a relatively small two storey detached office located on 252 the University of Plymouth campus. The original building was constructed as a timber workshop in the

- 253 18th Century and has since been extended over the years to convert into an office building. Reflecting
- 254 this historic development, the construction comprises of a variety of materials, though the external
- walls were a mixture of rendered solid stone and uninsulated rendered brick / block (Masonry) cavitywalling.
- 257

In 2019 this building received extensive internal and external renovation. Whilst this regime of
 improvements did not include additional insulation to the external walls, one major intervention was
 the installation of an externally planted living wall.

261

262 The living wall used for this building is the modular 'Fytotextile' system, which was supplied by 263 Scotscape [59]. This flexible felt fabric sheet system is made up of waterproof synthetic layer, 264 absorbent moisture layer (middle layer) and porous outer felt layer and makes use of these to form 265 pockets for soil and planting. The tested LWS uses a mixture of evergreen plant types including sedges 266 (Carex spp), ferns (e.g. Dryoteris spp), rushes (e.g. Luzula spp) and flowering shrubs (e.g. Sarcocca 267 confusa). Plants were installed with a standard multi-purpose potting compost. These fytotextile 268 sheets are fixed to the wall via a frame and plants are watered using a tubular drip-irrigation system 269 from above the sheets. Figure 1 shows a photograph of the system used in this study.

270



271272 Figure 1. Photo of the Fytotextile living wall system.

273



Figure 2. Cross section through the wall showing diagrammatic location of sensors.

The living wall was installed on the west and south elevations to the building. These elevations were
selected for their ease of retrofit and comprised of masonry cavity wall construction. Figure 2
presents a section through the cavity wall, showing the attachment of the Fytotextile living wall
system. Figure 3 shows a photo of the case study building, which illustrates the extent of the living
wall system.



Figure 3. Photo of case study building, showing locations of monitoring setup.

285

- 286 To verify the inner wall construction of the masonry cavity wall, an invasive inspection was carried out
- using a borescope inserted into a small drill hole in the wall. It was deemed through the identification
- **288** of the constituent materials that the masonry wall was constructed before the 1970s.
- 289

290 Illustrated in figure 2, the existing wall comprised of an inner leaf of dense concrete block (125mm) 291 and an outer leaf of brick (105mm). These layers were separated by a 50mm uninsulated cavity. The 292 internal face of the wall was finished with a gypsum plaster (13mm). The external face of the wall was 293 finished with a painted render finish (25mm). The render had a rough cast finish. The exact physical 294 properties of these materials were not known due to the limited access for destructive investigation, 295 however it is possible to estimate the theoretical U-value, calculated from data provided by CIBSE 296 [60]. Using a medium density concrete block at 0.77W/mK and external leaf brick at 0.84W/mK, with 297 a cementitious render (1.13W/mK) and gypsum plaster (0.18W/mK), a predicted U-value for the wall could be calculated to be $1.37W/m^{2}K$.

298 299

300 3.2 Monitoring methodology

To investigate the difference in thermal transmission between an existing cavity wall covered with an
 outer layer of living wall vegetation and one without, two sets of heat flux sensors were installed to
 monitor the thermal conductivity of the two wall locations:

304 305

306

307

- Location 1. Uninsulated masonry wall.
- Location 2. Uninsulated masonry wall with external living wall façade.

Figure 4 shows a plan of the building, indicating the locations of the monitoring setup locations andthe living wall locations.





- 311
- Figure 4. Building plan showing location of monitoring locations (red) and extent of living walling(Green).
- 314
- 315 It is important to note that these two locations were in separate room zones. For each zone, the air
- temperature was monitored. The results from each zone would be used in part to calculate the in-situ
- **317** U-value for the wall. As illustrated in figure 4, the design of the case study meant that it was not
- **318** possible to monitor the two different wall states in the same space.
- 319

320 There are several methods for measuring and calculating the in-situ U-value of an existing building

- 321 construction. Hukseflux [61] outline a method of monitoring a construction build-up using internally322 wall mounted heat flux sensors alongside thermocouples, which attached to the internal and external
- surfaces of the construction. A variation to this method is presented by the Building Research
- 324 Establishment (BRE) [62], who utilise a similar method derived from BS ISO 9869-1:2014, which is
- known as the 'average method' [63]. Within the average method, surface temperatures are replaced
- 326 with measurements of internal and external air temperatures. The average method of in-situ U-value
- 327 calculation is discussed by others in relation to monitoring existing wall constructions [64-67]. For the
- 328 case study in this paper, the average method of in-situ U-value measurement was chosen.
- 329
- Monitoring was undertaken from 18:00 on 7th November 2019 to 18:00 on 12th December 2019. This
 five-week period was selected due to its forecast of seasonally cool external temperatures, and with
- knowledge that the internal heating system would be on throughout the investigation period.
- 333
- **334** For this experiment two sets of calibrated HFP01 HFM sensors were used for these experiments [61].
- A T620bx thermal camera [68] was used to help determine the most appropriate location for
- measurement [63], which avoided thermal bridges and known defects. Sensors were also placed away
- from room corners and window jambs to minimise the effects of thermal bridging [64]. All sensors
- were positioned at equal heights from floor level and equal horizontal distances from masonry wall
- ends to limit the variability of the masonry walling between the two measurement locations. This
- would also help to minimise the variability in external climatic conditions and their effect on the twowall locations. For example, wind driven convection, precipitation and solar radiation.
- 342
- For each of the two setups, two heat flux sensors were taped to the internal face of the wall to be
 measured using a heat sink compound applied between the sensor and wall. An average reading was
 calculated between the two sensors and used in later analysis.
- 346
- 347 Each set of heat flux sensors were connected to a calibrated Campbell Scientific CR1000 data logger
 348 [69], which were used to collect data for the experimental period. At the end of the experiment, the
 349 data was downloaded and analysed to determine the in-situ U-value.
- 350

To aid comparison between the two data sets, sensors were placed on the same external wall, less
than 10m apart and faced the same orientation, therefore being exposed to the same climatic
conditions.

354

The methodology for the heat flux experiment was developed in accordance with ISO 9869-1:2014 [63], and previous work by Asdrubali *et al.* [70] and Baker [9, 64]. For the monitoring period a 15minute temporal resolution for data collection was selected. All the apparatus was coordinated so that measurements were recorded at the same time. In selecting the duration of the experimental period, Biddulph *et al.* [71] recommend a three week data collection period, while Baker [64] recommends monitoring for 27 days. Because the building being inspected would be in constant use during the experiment, it was decided that a five-week data collection period would be used.

- 362
- For the internal and external air temperatures four Hobo MX1101 data loggers [72] were used. Each
 wall state had a pair of data loggers, where one was located on the outside close to the monitoring
 location and the other was located inside close to the heat flux sensor setup. The data from these was
 validated by further collecting air temperature data using a wireless weather station, which was used
 to monitor external climatic conditions prior to and during the experimental period.
- 368
- 369 3.3 Analysis equation

370 Data from all sources of apparatus was downloaded at the end of the monitoring period and collated
371 in excel where it was reviewed to calculate the moving average thermal transmission for each section
372 of walling. [61-63]. The equation used was taken from the BRE average method for in-situ U-value
373 calculation [62]:

374

 $U = \frac{Q}{T_i - T_e} = \frac{Q}{\Delta T}$

376 377

379

375

378 Equation 1. In-situ U-value equation [62]

380 In order to evaluate the thermal transmission over time, this equation can be modified to take381 account of consecutive data in a moving average equation:

382 383

384

385

386

387

 $U_t = \frac{\sum Qi}{\sum (T_i - T_e)i} = \frac{\sum Qi}{\sum \Delta Ti}$

- **388** Equation 2. Moving average in-situ U-value equation [64].
- 389390 Where:
- **391** U_t = Average U-value over *t* hours (W/m²K)
- **392** $\Sigma Qi =$ Heat flux at interval of *i* hours (W/m²)
- **393** $\Sigma \Delta Ti$ = Temperature difference between internal and external space at interval of *i* hours (K)

395 4. Results

396 4.1 Monitoring results

- **397** Data from each of the monitoring tools was collected at the end of the five-week study period.
- 398

394

Internal air temperature results presented a pattern that clearly showed when the space heating
turned on and off during a daily cycle. Weekends were distinguishable due to the absence of space

- 401 heating during this two-day period. The average internal air temperature for this study period was
- **402** 17.2°C (±4.2°C fluctuations). External air temperatures varied from between 5°C and 12°C during the
- 403 study period, with a high of 15°C and low of 1.5°C. The average external air temperature was 8.9°C
 404 (±6.8°C fluctuations).
- 405
- 406 The 15-minute spaced data interval was calculated using U-value
- 407 Equation 1 as a first step to analysis. The results from this are presented in Figure 5.
- 408



⁴⁰⁹ 410

Figure 5. 15-minute data interval U-value results for 5-week study period.

411412 Uninsulated masonry wall without living facade

- Highest measured U-value: 4.67W/m²K
- Lowest measured U-value: 0.07W/m²K
- Spread between values: 4.60W/m²K
- 415 416

418

419

413

414

- 410 417 Uninsulated masonry wall with living façade
 - Highest measured U-value: 2.26W/m²K
 - Lowest measured U-value: 2.20W/m K
 - Spread between values: 2.05W/m²K
- 420 421

422 Figure 6 takes a five-day period from Monday 25th to Friday 29th November and focuses in more detail

423 to observe the fluctuations of each wall state over a shorter period. This shows the difference in

- 424 measurement fluctuations between the two wall states.
- 425



426 427

Figure 6. 15-minute data interval U-value results for 5-day study selection.

428

429 Following initial analysis on the 15-minute interval data, the data set was next calculated using

430 Equation 2 to determine the moving average U-value for the two wall states. Results for each wall

431 state are plotted in Figure 7 and show the moving average values plotted against the internal and

432 external air temperatures. These results show how the moving average U-values began to level out

433 after the first week of monitoring. This is likely due to the low variance in internal and external air434 temperature fluctuations. The most significant fluctuation being the drop in external air temperature

- 435 to 1.5° C on the morning of Monday 2^{nd} December.
- 436



437 438

439

440 441

442

443 444

445

446

Figure 7. Moving average U-value results for 5-week study period. Also showing internal and external air temperatures.

At the end of the moving average calculation period a final U-value was recorded, which accounts for the full monitoring period. These were:

- Final U-value for cavity masonry wall with the living wall façade: 0.77W/m²K
- Final U-value for cavity masonry wall <u>without</u> the living wall façade: 1.12W/m²K

When compared with literature benchmarks, the measured U-value for the uninsulated masonry
cavity wall compares well, as similar measurements by Baker [9] found U-values in the region of 1.3 to
1.1W/m²K. This therefore places the study wall within Bakers' lower range for similar wall
constructions. Furthermore, the existing walling performs better than estimated when calculated
using theoretical data. This last point also serves to highlight the challenge when seeking to predict
as-built / existing fabric U-values on existing buildings.

453

454 An alternative method to calculate a given wall's U-value is to undertake a desktop calculation in

- 455 accordance with Anderson [16] per BS EN ISO 6946 [17]. Yet difficulties in ascertaining information456 such as the pre-existing brick and block types, and their specific thermal conductivity values could
- 456 such as the pre-existing brick and block types, and their specific the457 limit the accuracy and significance of such an exercise.
- 458

459 4.2 Uncertainty analysis

460 Measurements from heat flux analysis will contain a degree of inaccuracy, largely due to variables

- 461 within the surrounding environment and monitoring equipment [73]. For this reason, uncertainty
- 462 analysis of the in-situ U-value calculations were undertaken to better understand the potential for
- 463 error. The method of uncertainty analysis used for these experiments was the 'root mean square'
- **464** (RMS) method, which followed the approach used by Baker [9].

- 465
 466 The sensitivity of each part of each equation was determined before conducting a RMS uncertainty
 467 equation. The resultant product indicated the uncertainty (±) of the calculated U-value.
 468
 - 469 For each measurement, an uncertainty, δU , can be introduced:
 - 470 471

- $U_t \pm \delta U_t = \frac{\sum Q \pm \delta Q}{\sum ((T_i \pm \delta T_i) (T_e \pm \delta T_e))}$
- 472 Equation 3. Uncertainty analysis equation
- 473 474

To begin with, measurement errors were determined for each part of the applied equations and for the apparatus used. Accuracy data for the hardware gives uncertainties of ± 5 % for δQ , recorded by the heat flux sensor [61] and $\pm 0.21^{\circ}$ C in the range of 0°C to 50°C for δT_e and δT_i , recorded by the data loggers [74].

480 To perform the uncertainty analysis, each U-value equation was re-run, though this time each error
481 was factored in, one at a time. Once all of the errors had been processed through the U-value

482 equations, a RMS equation was conducted to derive the overall uncertainty of the U-value.

483

479

484 It should be noted that a greater degree of result uncertainty is to be expected from unknown

- 485 constructions, or those with limited information. Ficco *et al.* [75] report on this issue, estimating an
- 486 uncertainty of between 14% and 33% for constructions where material properties are unknown.
- 487
- 488 Table 1. Uncertainty analysis for both wall states.

Wall State	Final moving average calculated U-Value (W/m2K)	U-value uncertainty ± (W/m2K)	Percentage uncertainty ± from calculated (%)
Masonry Cavity Wall with Living Wall Façade	0.77	0.07	8.70%
Masonry Cavity Wall without Living Wall Façade	1.12	0.10	8.71%

489

490 Table 1Error! Reference source not found. shows that for each wall states the uncertainty in final
491 moving average calculated U-value results were no more than ±0.10W/m2K. This degree of
492 uncertainty corresponds with similar findings by [9], who calculate a ±0.11W/m2K (±8%) uncertainty
493 for walls with a temperature difference between inside and outside of at least 8.3K. The temperature

- 494 difference in this study was on average 8.26K.
- 495

496 5. Discussion

497 Initial comparison between the indoor air temperatures of the two separate rooms found that the

498 larger room, which had the external living façade, presented narrower fluctuations in temperature

499 variation compared with the room which did not have a living wall façade (figure 7). Whilst it is

500 possible that the in-situ U-value for the two scenarios could be influenced by the different room

temperatures, on closer analysis, the temperature difference between the two rooms was on average

502 0.3°C, and never exceeded a 2.5°C difference. The close similarity between room air temperatures

- **503** was deemed to be of limited significance to the overall results.
- 504

505 Another factor that should be considered with the results is the location of the sensors in relation to

- the surrounding built forms. As previously discussed, care was taken to place all sensors in both
- 507 locations with minimal variation in location differences. Whilst it was not possible to completely
- 508 mitigate for variation, it is important to consider the un-controllable effects of such variations with509 this case study building. One example was the location of the non-living wall sensor close to an
- 509 this case study building. One example was the location of the non-ining war sensor close to 510 intersecting external wall. The effect of this external feature might have led to increased air
- 511 turbulence at the corner. Lower air movement at this point might have resulted in an increased
- 512 surface boundary layer and therefore variation in measured U-value.
- 513

As the review section of this paper indicates, a number of authors working in various fields suggest that green and living walls have the potential to provide a wide range of benefits both to the building occupants, and the local environment. Unfortunately, the review showed that there was less reliable information to guide a designer that might wish to assess how much an existing masonry building could be thermally improved in real conditions. Smaller scale results in more controlled environments can provide some precise measurement and associated themes that the study of a real building can then reflect and often substantiate.

- 521
- 522 From the case study findings it was found that by applying
- 523 Equation 1 to each logged data interval, presented in Figure 5, it was clear that the U-value for the

524 wall without the LWS cladding was greater than the wall which had the external living wall system.

- 525 Analysing this further it became apparent that this was the case for 86.4% of all measurements. These
- 526 initial findings suggest that the addition of a LWS could help to lower the heat loss from an external
- 527 wall.
- 528

529 Figure 6 focuses in on a narrower 5-day band, presenting the difference in calculated results for each 530 logged interval in greater clarity. It can also be seen from this graph how the diurnal temperature 531 fluctuations for the wall with the LWS cladding is more gradual than the wall without the LWS 532 cladding, which shows greater fluctuation over the same period. The patterns in heat loss at night for 533 the two walls appears closer than experienced during the daytime. While this could be said to 534 contradict findings by Nan et al. [40], who suggest that the insulating benefits from LWS might be 535 expected in the evening or early morning, it might be explained by the use of the building. For 536 instance, the heating period for this office building was during the day, with the heating system 537 turned off during the evening, night and weekend periods. This is quite different to a domestic 538 heating regime. The results therefore show that the greatest insulating benefit is had when the

- heating system is at its highest, which correlates with findings by Riley [33].
- 540

541 By reviewing the moving average results over the five-week study period (Figure 7), it became even
542 more apparent that the final U-value for the wall with the addition of an external LWS façade was
543 lower than the U-value for the wall without the LWS. This is significant, since it represents a

544 0.35W/m²K improvement by simple addition of substrate and plant layer to the outside of the wall.

- 545 This equates to a 31.4% improvement over the original wall state. Further investigations are planned
- 546 that include assessments of the impact of different substrates and planting regimes upon the
- 547 measured U value alongside connected variables such as irrigation schedules and variances in living
- 548 wall moisture retention.
- 549

550 Comparisons can be made between the final U-value for the masonry wall with the LWS façade

- cladding and alternative insulation treatments, which could be applied to this masonry cavity wall
- construction. In a report for SAP, the BRE [76] present several options for cavity wall improvements.
- 553 Starting with an average measured U-value for an un-insulated cavity wall of 1.43W/m²K, for similar
- aged cavity walls (walls built before 1976), the BRE estimate that filling the empty cavity with
- 555 insulation could bring the U-value down to $0.7W/m^2K$.

- 556
- 557 A range of additional measures were presented in the BRE report, which brought the theoretical U-
- value down further, such as adding cavity insulation and internal or external insulation. However, the
- 559 findings from this study have demonstrated that by adding a LWS façade to a similar aged masonry
- cavity wall, improvements in fabric U-value could match those expected from fully filling the cavity.
- 561

562 6. Conclusion

- **563** This paper has examined existing thermally related green and living wall research and in response to a
- 564 lack of real building-based studies, explored the difference in thermal transmission between a pre
 565 1970s uninsulated brick and block cavity wall and the same wall construction with a living wall system
 566 façade cladding fixed to the external face of the wall.
- 567

568 Overall findings from this study led to the calculation of a U-value for this LWS façade location, which 569 was a 31.4% improvement over the original as built state of the same wall. Furthermore, analysis of 570 the results showed that the diurnal fluctuations in U-value results were less varied over the study 571 duration, with results varying by 2.05W/m²K for the wall with the LWS façade compared with the 572 standard state wall, which varied by 4.60W/m²K over the same period.

- 573
- Whilst this study is not representative of all situations and wall types, the findings suggest that adding
 a LWS to the façade of an uninsulated cavity masonry wall could be used to lower heat losses in
 addition to bringing many other benefits, such as increased biodiversity, sound absorption and
 reductions in air pollution.
- 577 578

579 The findings of this study suggest that there is a lack of empirical data on effects of living wall planting 580 substrate on building insulation. The choice of planting substrate is potentially more significant to the 581 insulation properties of living wall systems than plant choice. Substrates such as low-density soils with 582 a high volume of air spaces and organic matter potentially provide increased thermal insulation in 583 living wall systems. Research by O'Donnell et al. [77] on arctic permafrost show clearly that the 584 thermal conductivity of organic rich soils is typically lower than that of mineral soils. O'Donnell et al. 585 [77] also show that thermal conductivity of soils is closely linked to moisture content, bulk density, 586 and water phase within the soil.

587

588 The aspects that are highlighted alongside the work presented in this paper forms the basis for a 589 larger study that will investigate the insulative benefits that an external living wall can deliver for 590 existing buildings. As part of the larger study, future works shall explore the effect that organic matter 591 has on thermal performance. Investigating the effect that irrigation has on soil conductivity, whether 592 different plant species offer varied improvements in performance. Repeat investigations to this study 593 will explore the effect that annual growth has on overall performance.

- 594
 595 Further work is also required on the effect of plant type on building insulation and whether mixed
 596 species plantings are more or less effective in providing shade and thermal insulation than single
 597 species plantings. It is important that plant choice in living wall systems reflects not only the aesthetic
 598 requirements but maximises wider environmental and ecosystem service needs such as biodiversity
- solution and cosystem service needs such as enhancement, carbon sequestration as well as increasing building energy efficiency.
- 600

In addition, future work will monitor the temperatures at material boundaries throughout the entire
 construction to investigate the fluctuations throughout the layers. Investigations of the building's
 marphology shall also be investigated to better understand the positive or pogative effects that wind

- morphology shall also be investigated to better understand the positive or negative effects that windmovement might have on external walls with or without a living wall. Studies shall also be conducted
- 605 on other buildings, construction types, different orientations and at different times of year to

- ascertain whether a living wall can deliver similar performance benefits to other buildings and in bothheating and cooling seasons.
- 608

609 7. References

- 610 [1] CCC. The Sixth Carbon Budget Buildings. In: Change CoC, editor. London, UK: UK
- 611 Government; 2019.
- 612 [2] Palmer J, Cooper I. Great Britain's housing energy fact file 2011. In: Department of
- 613 Energy and Climate Change (DECC), editor.: Cambridge Architectural Research, Cambridge
- 614 Econometrics and Eclipse, with data provided by BRE; 2011.
- 615 [3] DCLG. English Housing Survey. Housing stock report 2008. In: Communities and Local
- 616 Government & National Statistics, editor. London, UK: Crown Copyright; 2010.
- 617 [4] DCLG. English Housing Survey. Headline Report 2012-13. In: Department for
- 618 Communities and Local Government, editor. London, UK: Department for Communities and619 Local Government; 2014.
- 620 [5] VOA. Stock of Property by region, sector and building age as at 31 March 2015. In:
- 621 Valuation Office Agency, editor.: Gov.uk; 2015.
- 622 [6] DECC. The Carbon Plan: Delivering our low carbon future. In: Department of Energy &
- 623 Climate Change (DECC), editor. London: Crown Copyright, Department of Energy & Climate 624 Change; 2011. p. p 220.
- [7] CCC. Net Zero: The UK's contribution to stopping global warming. In: Change CoC, editor.London, UK: UK Government; 2020.
- 627 [8] DECC. Statistical Release: Experimental Statistics: Estimates of Home Insulation Levels in
- Great Britain: April 2013. In: DECC, editor. London: Department of Energy & Climate Change;2013.
- 630 [9] Baker P. 🕮-values and traditional buildings. In situ measurements and their
- 631 comparisons to calculated values: Historic Scotland 2011.
- [10] SAP. Consultation Paper: CONSP:16: Review of default U-values for existing buildings in
 SAP. SAP Supporting Document: Building Research Establishment Ltd; 2016.
- 634 [11] Lowe R, Bell M. Towards Sustainable Housing: building regulation for the 21st century.
- A report prepared for the Joseph Rowntree Foundation. Leeds, UK: Centre for the Built
- 636 Environment, Leeds Metropolitan University; 1998.
- [12] Paraschiv L, Spiru P, Ion I. Increasing the energy efficiency of buildings by thermalinsulation. Energy Procedia. 2017;128:393-9.
- 639 [13] Šujanová P, Rychtáriková M, Sotto Mayor T, Hyder A. A Healthy, Energy-Efficient and
- 640 Comfortable Indoor Environment, a Review. Energies. 2019;12:1414.
- 641 [14] Sadineni SB, Madala S, Boehm RF. Passive building energy savings: A review of building
- 642 envelope components. Renewable and Sustainable Energy Reviews. 2011;15:3617-31.
- 643 [15] Ottelé M, Perini K, Fraaij ALA, Haas EM, Raiteri R. Comparative life cycle analysis for
- 644 green façades and living wall systems. Energy and Buildings. 2011;43:3419-29.
- [16] Anderson B. Conventions for U-value calculations. In: Scotland B, editor. Bracknell: BREPress; 2006.
- 647 [17] Building components and building elements Thermal resistance and thermal
- transmittance Calculation method. BS EN ISO 6946:2007: BSi; 2008.
- 649 [18] Sanders CH. Ventilation of the Cavities in Timber Framed Walls. In: Agency SBS, editor.
- 650 Glasgow: Centre for Research on Indoor Climate and Health School of Engineering, Science
- and Design Glasgow Caledonian University; 2005.

- [19] Davies IP. Moisture conditions in external timber cladding: field trials and their designimplications: Edinburgh Napier University; 2011.
- [20] Palermo SA, Turco M. Green Wall systems: where do we stand? IOP Conference Series:Earth and Environmental Science. 2020;410:012013.
- 656 [21] Besir AB, Cuce E. Green roofs and facades: A comprehensive review. Renewable and
 657 Sustainable Energy Reviews. 2018;82:915-39.
- 658 [22] Azkorra Z, Pérez G, Coma J, Cabeza LF, Bures S, Álvaro JE, et al. Evaluation of green
- walls as a passive acoustic insulation system for buildings. Applied Acoustics. 2015;89:46-56.
- 660 [23] Radic M, Brković Dodig M, Auer T. Green Facades and Living Walls—A Review
- 661 Establishing the Classification of Construction Types and Mapping the Benefits.
- 662 Sustainability. 2019;11.
- 663 [24] Casas B, Isabelle E. Bird use of living walls in the city of Bogot, Colombia. 2016.
- 664 [25] Collins R, Schaafsma M, Hudson MD. The value of green walls to urban biodiversity.
- 665 Land Use Policy. 2017;64:114-23.
- 666 [26] Maron A, Ramirez F. Social Perception of Living Walls in Quito: A Study of Four Vertical
- 667 Gardens. IOP Conference Series: Earth and Environmental Science. 2020;503:012095.
- 668 [27] Weinmaster M. Are Green Walls as "Green" as They Look? An Introduction to the
- 669 Various Technologies and Ecological Benefits of Green Walls. Journal of Green Building.
- 670 2009;4:3-18.
- [28] Perini K, Ottele M, Haas EM, Raiteri R. Greening the building envelope, facade greeningand living wall systems. Open Journal of Ecology. 2011;Vol.01No.01:8.
- 673 [29] H. F. Di DNW. COOLING EFFECT OF IVY ON A WALL. Experimental Heat Transfer.
- 674 1999;12:235-45.
- [30] Wong NH, Kwang Tan AY, Chen Y, Sekar K, Tan PY, Chan D, et al. Thermal evaluation of
- 676 vertical greenery systems for building walls. Building and Environment. 2010;45:663-72.
- [31] Safikhani T, Baharvand M. Evaluating the effective distance between living walls andwall surfaces. Energy and Buildings. 2017;150:498-506.
- [32] Cameron RWF, Taylor JE, Emmett MR. What's 'cool' in the world of green façades? How
- 680 plant choice influences the cooling properties of green walls. Building and Environment.
- 681 2014;73:198-207.
- [33] Riley B. The state of the art of living walls: Lessons learned. Building and Environment.2017;114:219-32.
- 684 [34] Marchi M, Pulselli RM, Marchettini N, Pulselli FM, Bastianoni S. Carbon dioxide
- 685 sequestration model of a vertical greenery system. Ecological Modelling. 2015;306:46-56.
- 686 [35] Gusyachkin AM, Sabitov LS, Khakimova AM, Hayrullin AR. Effects of moisture content
- 687 on thermal conductivity of thermal insulation materials. IOP Conference Series: Materials
- 688 Science and Engineering. 2019;570:012029.
- 689 [36] Tangjuank S. Thermal insulation and physical properties of particleboards from
- 690 pineapple leaves. International Journal of Physical Sciences. 2011;6:4528-32.
- 691 [37] Eumorfopoulou EA, Kontoleon KJ. Experimental approach to the contribution of plant-
- 692 covered walls to the thermal behaviour of building envelopes. Building and Environment.
- 693 2009;44:1024-38.
- [38] Cameron RWF, Taylor J, Emmett M. A Hedera green façade Energy performance and
- 695 saving under different maritime-temperate, winter weather conditions. Building and
- 696 Environment. 2015;92:111-21.



- [39] Yoshimi J. The thermal effects of green roofs and walls: Experimentation on the
- 698 performance of vegetated building envelopes in the UK. Sheffield: University of Sheffield;699 2016.
- [40] Nan X, Yan H, Wu R, Shi Y, Bao Z. Assessing the thermal performance of living wall
- systems in wet and cold climates during the winter. Energy and Buildings. 2020;208:109680.
- 702 [41] Charoenkit S, Yiemwattana S. Living walls and their contribution to improved thermal
- comfort and carbon emission reduction: A review. Building and Environment. 2016;105:82-94.
- [42] Carlos JS. Simulation assessment of living wall thermal performance in winter in theclimate of Portugal. Building Simulation. 2015;8:3-11.
- 707 [43] Rupp AIKS, Gruber P. Biomimetic Groundwork for Thermal Exchange Structures Inspired708 by Plant Leaf Design. Biomimetics. 2019;4:75.
- 709 [44] Leigh A, Sevanto S, Close JD, Nicotra AB. The influence of leaf size and shape on leaf
- thermal dynamics: does theory hold up under natural conditions? Plant, Cell & Environment.2017;40:237-48.
- [45] Wang C, He J, Zhao T-H, Cao Y, Wang G, Sun B, et al. The Smaller the Leaf Is, the Faster
 the Leaf Water Loses in a Temperate Forest. Front Plant Sci. 2019;10:58-.
- 714 [46] Bau-Show L, Yann-Jou L. Cooling Effect of Shade Trees with Different Characteristics in a
- 715 Subtropical Urban Park. HortScience horts. 2010;45:83-6.
- 716 [47] Doughty CE, Santos-Andrade PE, Shenkin A, Goldsmith GR, Bentley LP, Blonder B, et al.
- 717 Tropical forest leaves may darken in response to climate change. Nature Ecology &
 718 Evolution. 2018;2:1918-24.
- 719 [48] Scarpa M, Mazzali U, Peron F. Modeling the energy performance of living walls:
- 720 Validation against field measurements in temperate climate. Energy and Buildings.
- 721 2014;79:155-63.
- 722 [49] Jim CY, He H. Estimating heat flux transmission of vertical greenery ecosystem.
- 723 Ecological Engineering. 2011;37:1112-22.
- 724 [50] Yoshimi J, Altan H. Thermal simulations on the effects of vegetated walls on indoor
- building environments. Proceedings of Building Simulation2011. p. 1438-43.
- 726 [51] De Masi RF, de Rossi F, Ruggiero S, Vanoli GP. Numerical optimization for the design of
- 727 living walls in the Mediterranean climate. Energy Conversion and Management.
- 728 2019;195:573-86.
- 729 [52] Cuce E. Thermal regulation impact of green walls: An experimental and numerical
- 730 investigation. Applied Energy. 2017;194:247-54.
- 731 [53] Abd el-aziz Amr, Hosam, Elkhiary, Ayah. Investigating the Cooling Effect of Living Walls.
- 732 In: Gorse PC, Scott PL, editors. Green Heritage International Conference. British University of
- 733 Egypt: Leeds Sustainability Institute. SEEDS; 2018. p. 49-64.
- 734 [54] Pulselli RM, Pulselli FM, Mazzali U, Peron F, Bastianoni S. Emergy based evaluation of
- environmental performances of Living Wall and Grass Wall systems. Energy and Buildings.2014;73:200-11.
- 737 [55] Sánchez-Reséndiz JA, Ruiz-García L, Olivieri F, Ventura-Ramos E. Experimental
- assessment of the thermal behavior of a living wall system in semi-arid environments of
 central Mexico. Energy and Buildings. 2018;174:31-43.
- 759 Central Mexico. Ellergy and Bullulings. 2010,174.51-45.
- [56] Mazzali U, Peron F, Romagnoni P, Pulselli RM, Bastianoni S. Experimental investigation
- on the energy performance of Living Walls in a temperate climate. Building and
- 742 Environment. 2013;64:57-66.

- 743 [57] Manso M, Castro-Gomes JP. Thermal analysis of a new modular system for green walls.
- 744 Journal of Building Engineering. 2016;7:53-62.
- [58] Tudiwer D, Korjenic A. The effect of living wall systems on the thermal resistance of thefaçade. Energy and Buildings. 2017;135:10-9.
- 747 [59] Scotscape. Fytotextile The lightest Living Wall system on the UK market. London, UK:
 748 Scotscape; 2018.
- [60] CIBSE. Environmental design. CIBSE Guide A. 7th Edition ed. London, UK: The Chartered
 Institution of Building Services Engineers; 2018.
- [61] Hukseflux. HFP01 & HFP03 Heat Flux Plate / Heat Flux Sensor. Delft, NL: Hukseflux
 Thermal Sensors; 2021.
- [62] Kosmina L. Guide to In-situ U-value measurement of walls in existing dwellings. In-situ
 measurement of U-value. Watford, UK: BRE; 2016.
- 755 [63] ISO. ISO 9869-1:2014. Thermal insulation Building elements In-situ measurement of
- thermal resistance and thermal transmittance Part 1: Heat flow meter method:
- 757 International Organization for Standard,; 2014.
- [64] Baker P. In situ U-value measurements in traditional buildings preliminary results:
 Historic Scotland; 2008.
- 760 [65] Bienvenido-Huertas D, Rodríguez-Álvaro R, Moyano JJ, Rico F, Marín D. Determining the
- 761 U-Value of Façades Using the Thermometric Method: Potentials and Limitations. Energies.762 2018;11:360.
- [66] Gaspar K, Casals M, Gangolells M. A comparison of standardized calculation methods
 for in situ measurements of façades U-value. Energy and Buildings. 2016;130:592-9.
- 765 [67] Marshall A, Fitton R, Swan W, Farmer D, Johnston D, Benjaber M, et al. Domestic
- building fabric performance: Closing the gap between the in situ measured and modelled
- 766 building fabric performance. Closing the gap between the in situ measured and767 performance. Energy and Buildings. 2017;150:307-17.
- [68] FLIR. FLIR T620bx 25° (incl. Wi-Fi). Technical Data. Wilsonville, USA: FLIR Systems, Inc.;
 2013. p. 12.
- [69] Campbell Scientific. CR1000 Measurement and Control Datalogger. Campbell Scientific;2014.
- 772 [70] Asdrubali F, D'Alessandro F, Baldinelli G, Bianchi F. Evaluating in situ thermal
- transmittance of green buildings masonries—A case study. Case Studies in Construction
 Materials. 2014;1:53-9.
- 775 [71] Biddulph P, Gori V, Elwell CA, Scott C, Rye C, Lowe R, et al. Inferring the thermal
- resistance and effective thermal mass of a wall using frequent temperature and heat flux
- 777 measurements. Energy and Buildings. 2014;78:10 6.
- 778 [72] Onset. HOBO[®] U12 Temp/RH/Light/ External Data Logger Manual. (Part # U12-012).
- 779Bourne, MA, USA: Onset Computer Corporation; 2010.
- 780 [73] Nardi I, Ambrosini D, Rubeis Td, Sfarra S, Perilli S, Pasqualoni G. A comparison between
- thermographic and flow-meter methods for the evaluation of thermal transmittance of
- 782 different wall constructions. In: Paoletti D, Sfarra S, Ambrosini D, editors. 33rd UIT (Italian
- 783 Union of Thermo-fluid-dynamics) Heat Transfer Conference. L'Aquila, Italy: IOP Publishing;784 2015. p. 592.
- 785 [74] Onset. HOBO[®] MX1101 Data Logger. Bourne, MA: Onset Computer Corporation; 2015.
- 786 [75] Ficco G, Iannetta F, Ianniello E, d'Ambrosio Alfano FR, Dell'Isola M. U-value in situ
- 787 measurement for energy diagnosis of existing buildings. Energy and Buildings.
- 788 2015;104:108-21.

- 789 [76] BRE. Review of default U-values for existing buildings in SAP. Consultation Paper:
- 790 CONSP:162016.
- 791 [77] O'Donnell JA, Romanovsky VE, Harden JW, McGuire AD. The effect of moisture content
- on the thermal conductivity of moss and organic soil horizons from black spruce ecosystems
- in interior alaska. Soil Science. 2009;174:646-51.

building

Declaration of interests

⊠The authors declare that they have no known competing financial interests or personal relationships that could have appeared to influence the work reported in this paper.

The authors declare the following financial interests/personal relationships which may be considered as potential competing interests:

Journal Prevention